



NOTICE OF REVIEW

APDES Preliminary Draft Permit

Alaska Department of Environmental Conservation (DEC)
Wastewater Discharge Authorization Program
555 Cordova Street
Anchorage, Alaska 99501

NOTICE OF REVIEW OF AN ALASKA POLLUTANT DISCHARGE ELIMINATION SYSTEM (APDES) **PRELIMINARY DRAFT PERMIT** TO DISCHARGE TO WATERS OF THE UNITED STATES

ADEC has prepared an APDES preliminary draft permit for Golden Valley Electric Association (GVEA) Healy Power Plant. The Preliminary Draft Permit and associated documents are available to the applicant for a 10-day review. Following the close of the 10-day applicant review period, DEC will prepare a draft permit and fact sheet for a formal 30-day public review period. Public comments will be accepted during the formal 30-day review period. You can access the documents on DEC's Wastewater Discharge Authorization Program webpage at:
<http://www.dec.state.ak.us/water/wwdp/index.htm>

ADEC Contact: Marie Klingman
610 University Avenue
Fairbanks, AK 99709
(907) 451-2101
marie.klingman@alaska.gov

Preliminary Draft Permit Review:

Start Date: November 28, 2016
End Date: December 12, 2016

Permit No.: AK0022942

Applicant:

GVEA
Healy Power Plant
Mile 2.5 Healy Spur Road, Healy, AK 99743
758 Illinois Street, Fairbanks, AK 99707

Proposed Project and Location:

The discharge of GVEA Healy Power Plant once-through cooling water from coal-fired steam generators to the Nenana River. Outfall 001A discharges at 63° 51' 22.679" North (N) latitude

and 148° 57' 08.170" West (W) longitude, and Outfall 002A discharges at 63° 51' 25.622" N latitude and 148° 57' 02.744" W longitude. Discharge may be directed at either or both outfalls. A mixing zone is proposed for each outfall for temperature and iron.

Administrative Record:

The APDES preliminary draft permit, fact sheet, and associated documents are available for public review at the ADEC offices located in Anchorage, Fairbanks, Juneau, Soldotna, and Wasilla. Please contact the office of your choice to arrange for hard copies of the documents to be available for your review.

555 Cordova Street
Anchorage, AK 99501
907-269-6285

610 University Avenue
Fairbanks, AK 99709
907-451-2100

410 Willoughby Ave #303
Juneau, AK 99811
907-465-5300

43335 Kalifornsky Beach Road
Soldotna, AK 99615
907-262-5210

1700 E Bogard Road #B
Suite #103
Wasilla, AK 99654
907-376-1850

If you would like to see any additional supporting technical documents, contact Marie Klingman.

The documents are also accessible from the DEC website at:

<http://www.dec.state.ak.us/water/wwdp/index.htm>

Disability Reasonable Accommodation Notice

The State of Alaska, Department of Environmental Conservation complies with Title II of the Americans with Disabilities Act of 1990. If you are a person with a disability who may need a special accommodation in order to participate in this review, please contact Natalie Wolfe at (907) 269-0291 or TDD Relay Service 1-800-770-8973/TTY or dial 711 within 10 days of publication of this notice to ensure that any necessary accommodations can be provided.